



City of Seattle Pre-Application Site Visit Report

April 29, 2010

This report represents a preliminary determination of project requirements based on your Pre-Application Site Visit (PASV). The PASV Field Assessment and Report is completed by DPD site inspectors and is compiled from initial project information submitted by the applicant.

Project Summary

AP/Project No.	6246402	Ground Disturbance	Y
Application Template	BLDG	PASV Required This Permit	Y
Application Type	CONSTRUCTION AND DEVELOPMENT	Date PASV Completed	04/21/10
Category	INSTITUTIONAL	PASV Done Under	
DPD Review Type	FULL	Permit Remarks	
Address	3613 4th Ave S	Applicant	JOHN OVITT 700 5TH AVE #3300 PO BOX 34023 SEATTLE WA 981244023 (206) 684-3606
Location			
Zoning			
King County APN	7666205660		
Permit Status	Initial Information Collected		
Description of Work	Replace existing perimeter (security) fencing and gates to new higher standard.	Applicant Email	john.ovitt@seattle.gov
		Linked AP/Project Nos.	
SDOT Project No			

For detailed zoning information, click the King County APN number above, or visit <http://web1.seattle.gov/dpd/parceldata/> to find zoning details about your address.

Pre-Application Site Visit (PASV) Report

Contact: Roger E Moore, (206) 733-9039, Roger.Moore@seattle.gov

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:
Liquefaction

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (DR 16-2009, Volume 2). The CSC Best Management Practices (BMPs) noted below can be found in the Construction Stormwater Control Technical Requirements Manual, available online and from DPD's Public Resource Center.

Show the following on the CSC/Post Construction Soil Amendment Plan:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at: <http://web1.seattle.gov/DPD/InspectionRequest>

Inspectors Notes

No inspector notes.

Standard Submittal Requirements for Projects in an ECA

Site is mapped as liquefaction prone. Geotechnical report and/or structural calculations are required to address liquefaction potential and, if needed, mitigation (see SMC 25.09.100)

Applicant Next Steps

1. For questions on permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.
2. Review the requirements set forth in this report.
3. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
4. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**